



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

| | | | |
|---------------------|--|-------------|--------------------------------------|
| Certificate No.: | IECEx SIR 16.0096 | Page 1 of 4 | <u>Certificate history:</u> |
| Status: | Current | Issue No: 7 | Issue 6 (2022-01-28) |
| Date of Issue: | 2023-11-21 | | Issue 5 (2020-06-11) |
| Applicant: | MSA - The Safety Company 1000 Cranberry Woods Dr Cranberry Township, PA 16066-5296 United States of America | | Issue 4 (2019-04-26) |
| Equipment: | ALTAIR 4XR Multi Gas Detector | | Issue 3 (2018-03-21) |
| Optional accessory: | | | Issue 2 (2017-05-23) |
| Type of Protection: | Flameproof and Intrinsically Safe | | Issue 1 (2016-12-23) |
| Marking: | With XCell Ex Sensor Ex da ia IIC T3 Ga IEC 60079-29-1 Ta = -40°C to +60°C Ex ia I Ma Ta = -40°C to +60°C Without XCell Ex Sensor Ex ia IIC T3 Ga Ta = -40°C to +60°C Ex ia I Ma Ta = -40°C to +60°C Note: IEC 60079-29-1 applies to Group II only. | | Issue 0 (2016-10-25) |

Approved for issue on behalf of the IECEx
Certification Body:

Michelle Halliwell

Position:

Director Operations, UK & Industrial Europe

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

CSA Group Testing UK Ltd
Unit 6, Hawarden Industrial Park
Hawarden, Deeside CH5 3US
United Kingdom





IECEx Certificate of Conformity

Certificate No.: **IECEx SIR 16.0096**

Page 2 of 4

Date of issue: 2023-11-21

Issue No: 7

Manufacturer: **MSA - The Safety Company**
1000 Cranberry Woods Dr
Cranberry Township, PA 16066-5296
United States of America

Manufacturing locations: **MSA - The Safety Company**
1000 Cranberry Woods Dr
Cranberry Township, PA 16066-5296
United States of America

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-1:2014](#) Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

[IEC 60079-11:2011](#) Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

[IEC 60079-26:2014](#) Explosive atmospheres – Part 26: Equipment with Equipment Protection Level (EPL) Ga
Edition:3.0

[IEC 60079-29-1:2020](#) Explosive atmospheres – Part 29-1: Gas detectors – Performance requirements of detectors for flammable gases
Edition:2.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/CSAE/ExTR21.0191/00](#)
[GB/SIR/ExTR17.0073/00](#)
[GB/SIR/ExTR20.0090/00](#)

[GB/SIR/ExTR16.0248/00](#)
[GB/SIR/ExTR18.0050/00](#)
[GB/SIR/ExTR23.0176/00](#)

[GB/SIR/ExTR16.0329/00](#)
[GB/SIR/ExTR19.0123/00](#)

Quality Assessment Report:

[FR/INE/QAR08.0011/13](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx SIR 16.0096**

Page 3 of 4

Date of issue: 2023-11-21

Issue No: 7

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The MSA ALTAIR® 4XR is a handheld, battery operated, Multi-gas Detector with Bluetooth capabilities (optional) that can measure between 1 and 4 gases using a combination of the following MSA XCell® Sensors: one catalytic-bead combustible cell, one oxygen electrochemical cell and one dual toxic electrochemical cell. The enclosure is rectangular in shape, includes an LCD display window, and is manufactured from a non-metallic material with an overmold. There is an external connection that is only used for charging the battery and shall only be connected when located in a non-hazardous location.

Powered by a rechargeable Lithium Ion Polymer Battery Cell, Sony model US503759A8H, rated 3.8 V (nominal), 1400 mAh (nominal). MSA assembly number 10083913, or rechargeable Lithium Ion Polymer Battery Cell, Inventus Model IP583548, rated 3.8 V (nominal), 1435mAh (nominal), MSA assembly number 10242458.

Performance tested for 0-100% LFL methane, 0-100% LFL propane and other gas(es); 0-100% LFL n- Pentane. Altair 4XR firmware version 2.30 (English) or version 4.23 (French) and XCell Ex sensor firmware version 2.0. Performance temperature range: -20°C to +60°C as specified in Altair 4XR Addendum A manual 10175895.

Conditions of manufacture

The Manufacturer shall comply with the following:

1. The ALTAIR 4XR incorporates previously certified sensors. It is therefore the responsibility of the manufacturer to continually monitor the status of the certification associated with this device. The manufacturer shall inform Sira of any modifications to the device that may impinge upon the explosion safety design of the ALTAIR 4XR.

SPECIFIC CONDITIONS OF USE: NO



IECEx Certificate of Conformity

Certificate No.: **IECEx SIR 16.0096**

Page 4 of 4

Date of issue: 2023-11-21

Issue No: 7

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

This issue, Issue 7, recognises the following changes; refer to the certificate annex to view a comprehensive history:

1. Incorporate FS evaluation of firmware updates per CSA projects 80142606 and 80171531.
2. Assess alternate construction of Altair 4XR to include:
 1. New Li-Ion battery pack.
 2. Minor change to PCB to accommodate selecting a different charging voltage.
3. Update markings to reflect a new Temperature Code.
4. Updated schedule drawing and instructions with updated information.
5. Document Gas Performance Testing necessary for the above alterations.
6. Update approval standard from IEC 60079-29-1:2007 to IEC 60079-29-1:2016

Annex:

[IECEx SIR 16.0096 Iss 7 Annexe.pdf](#)

Annexe to: IECEx SIR 16.0096 Issue 7
Applicant: MSA - THE SAFETY COMPANY
Apparatus: ALTAIR 4XR multi gas detector



Full certificate change history

Issue 1 – this Issue introduced the following change:

1. Update the method of protection marking to reflect the change from “d” to “da” on the latest XCell Ex sensor certificates.

Issue 2 – this Issue introduced the following change:

1. It was recognised that these gas detectors have been subjected to the performance test requirements of IEC 60079-29-1:2007 Edition 1.

Issue 3 – this Issue introduced the following change:

1. The detector was allowed to be used for mining applications; as a consequence, the following marking was recognised:

With XCell Ex Sensor

Ex ia I Ma

Ta = -40°C to +60°C

Without XCell Ex Sensor

Ex ia I Ma

Ta = -40°C to +60°C

Issue 4 – this Issue introduced the following change:

1. Introduction of IEC 60079-26:2014 Edition 3, following the appropriate assessment to demonstrate compliance with the latest technical knowledge; IEC 60079-26:2014 Edition 3 was added to the list of standards.
2. Recognises a correction to the marking; to remove “da” from Without XCell Ex Sensor.

Issue 5 – this Issue introduced the following change:

1. Recognise an update to the firmware (R 2.27) within the Altair 4XR; the firmware change confirmed as having no effect on the gas measuring functions or safety aspects of the instrument.
2. Introduction of a new resin material for the calibration cap, RTP 2599 X 133889, to replace the obsolete resin material RTP 2599 X 97420D.
3. Introduction of an alternate sensor filter material, Cobetter PFOY-T1DT, to replace the obsolete filter material Versapor 1200R Hydrophobic.
4. Recognise an update to the firmware (R 2.28) within the Altair 4XR; the firmware change confirmed as having no effect on the gas measuring functions or safety aspects of the instrument.
5. Recognise a correction to the markings in Issue 4 of the Certificate due to a typographical error.
6. Equipment Description revised to recognizes: “Performance temperature range: -20°C to +60°C as specified in Altair 4XR Addendum A manual 10175895.”

Issue 6 – this Issue introduced the following change:

1. Following appropriate assessment for the existing product, standard IEC 60079-0:2011 (Edition 6) was replaced by IEC 60079-0:2017 (Edition 7).
2. Introduction of a new non-Bluetooth option (both non-safety critical components U16 and U18 would not be populated on the PCB).
3. Introduction of creating an option to populate the PCB with either the VQFN package or the UQFN package for the non-safety critical components U17 and U19 (U17 and U19 are the same part made by the same manufacturer).
4. Introduction of a new alternate PCB (P/N 10225260) to support the new alternate UQFN package for components U17 and U19 (as described above).
5. The Product Description was revised to call out the Bluetooth as optional; as per the introduced Non-Bluetooth option.
6. Scheduled drawing was revised to include the introduction of making non-Bluetooth an option and the introduction of an alternate PCB with UQFN package: Altair 4XR CSA schedule drawing.
7. Update of Addendum A to Altair 4X Operating Manual to include updated standard IEC 60079-0:2017

Issue 7 – this Issue introduced the following change:

1. Incorporate FS evaluation of firmware updates per CSA projects 80142606 and 80171531.
2. Assess alternate construction of Altair 4XR to include:
 - a. New Li-Ion battery pack.
 - b. Minor change to PCB to accommodate selecting a different charging voltage.

Annexe to: IECEx SIR 16.0096 Issue 7

Applicant: MSA - THE SAFETY COMPANY

Apparatus: ALTAIR 4XR multi gas detector



3. Update markings to reflect a new Temperature Code.
4. Updated schedule drawing and instructions with updated information.
5. Document Gas Performance Testing necessary for the above alterations.
6. Update approval standard from IEC 60079-29-1:2007 to IEC 60079-29-1:2016